Daily New Record Report Wurzel Ltd

Summary of Records Selected

Sites Monitored by Wurzel Ltd

Digi 33000205 Test site Wurzel Ltd Tx No. 1 Panel ID: 205 Uncommissioned Test site Wurzel Ltd 33000205

Installer: Wurzel Ltd Site Not Yet Commissioned

Police: SELECT POLICE FORCE Fire Service: SELECT FIRE BRIGADE Confirmation Required For Intruders: No Confirmation Required For PAs: No Password: None Duress Code: None

Default Remote Reset Type: None

AREAS

Number/Description:

O/C Mon Type: No O/C Monitoring

Last O/C Signal Recd:

No URNs available for this site

Available Site and Agency Action Contacts. See Sections below for other action types.

Site Actions

Group.1 MAIN SITE

Police Force

Group.1 SELECT POLICE FORCE

Fire and Rescue Service

Group.1 SELECT FIRE BRIGADE

Installer

Group.1 Wurzel Ltd		
Key Holder Details Key Holder Group No: 1	Main Key Holder Group	
K/H 1 (1) Cancel Alarms: YES Change Data: Normally Available	YES Change Times: YES Change KH:	YES Call List: YES
K/H 2 (2) Cancel Alarms: YES Change Data: Normally Available	YES Change Times: YES Change KH:	YES Call List: YES

Alarm Programming

Row Event Set Actions Unset Actions Method Linked URN:

1 Fire Alarm SO1FO1KO1KT1 SO1FO1KO1KT1 Automated SMS/Operator

Strategy:Wait Until Contact Becomes Available: - used for 1 action

2 Personal Attack PO1KO1KT1 PO1KO1KT1 Automated SMS/Operator

Strategy: Wait Until Contact Becomes Available: - used for 1 action

3 Intruder (Canc by Open) SO1KO1KT1 SO1KO1KT1 Automated SMS/Operator

Strategy: Wait Until Contact Becomes Available: - used for 1 action

4 Battery Fail KT1 KT1 Automated SMS

Strategy: Wait Until Contact Becomes Available: - used for 1 action

5 Mains Failure KT1 KT1 Automated SMS

Strategy:Wait Until Contact Becomes Available: - used for 1 action

6 Low Battery KT1 KT1 Automated SMS

Strategy: Wait Until Contact Becomes Available: - used for 1 action

8 Confirmed Intr Canc by SO1PO1KO1KT1 SO1PO1KO1KT1 Automated SMS/Operator

Op/Abt

Strategy: Wait Until Contact Becomes Available: - used for 1 action

9 Tamper Alarm NO1SO1KO1KT1 NO1SO1KO1KT1 Automated SMS/Operator

Strategy:Wait Until Contact Becomes Available: - used for 1 action

 Actions
 A Special instructions
 G General Agency
 M Medical Agency
 R Report

 Key
 C Reverse Chanel Command
 I Installer
 N Information Page
 S Site

F Fire Service K Key Holder Group P Police

No Active Alarm Notes

Transmitter Details

Transmitter No. 1: Digi Receiver Type: 33 Receiver

ID: 115:00:000205 Not Enabled Not Connected
Alarm Telno: N/A Panel Password: N/A Not Yet Signalled

Net Address 2: N/A Line Card 1: 33 Receiver

Password: None SW Version: N/A Panel Short Code: N/A

Transmitter Programming

Transmitter No. 1: Digi Receiver Type: 33 Receiver

Device Type: Zone/InputActivation EventRestore EventZone: 1Fire AlarmRestoreZone: 2Personal AttackRestore

Zone: 3 Intruder (Canc by Open) Restore Zone: 4 Open Close Zone: 5 Zone Omit Restore Zone: 7 Confirmed Intr Canc by Op/Abt Restore Zone: 8 Mains Failure Mains OK Zone: 9 **TEST SIGNAL Alt** Restore Zone: 10 Low Battery **Battery Restore** Zone: 80 **Battery Fail Battery Restore**

Zone: 844 NOW ON 0844 Restore

No Special Actions Set for this Site

Information Pages

 Status:
 Permanent
 Starts:

 Title:
 Digi Tamper Alarm Info Page
 Expires:

Any Tamper alarm following an intruder alarm treat as a confirmed (must be within 60 minutes and the

intruder must have not restored).

No User Defined Field Entries