

Daily New Record Report Wurzel Ltd

Summary of Records Selected

Sites Monitored by Wurzel Ltd

CSL Connected ARC Conn. Only CS9901

01184614

Windmill

Tx No. 1

Panel ID: 184614

Commissioned

Windmill
Windmill
Asthall
Burford
Oxfordshire
OX18 4HJ

01184614

User Ref: Windmill

Installer: Wurzel Ltd

Site Commissioned on 08/08/2024

Police: No Police Required

Fire Service: No Brigade Required

Confirmation Required For Intruders: No

Confirmation Required For PAs: No

Password: WURZEL

Duress Code: None

Default Remote Reset Type: None

AREAS

Number/Description: 1

O/C Mon Type: No O/C Monitoring

Last O/C Signal Recd: 08/08/2024 17:08:32

No URNs available for this site

Available Site and Agency Action Contacts. See Sections below for other action types.

Site Actions

Group.1 Main Site

Police Force

Group.1 No Police Required

Fire and Rescue Service

Group.1 No Brigade Required

Installer

Group.1 Wurzel Ltd

Key Holder Details

Key Holder Group No: 1

Main Key Holder Group

K/H 1 (1)

Cancel Alarms: ☐ YES Change Data: ☐ YES Change Times: ☐ YES Change KH: ☐ YES Call List: ☐ YES

Normally Available

K/H 2 (2)

Cancel Alarms: ☐ YES Change Data: ☐ YES Change Times: ☐ YES Change KH: ☐ YES Call List: ☐ YES

Normally Available

Alarm Programming

Row	Event	Set Actions	Unset Actions	Method	Linked URN:
1	Fire Alarm	SO1FO1KO1KT1	SO1FO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
2	Personal Attack	PO1KO1KT1	PO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
3	Intruder (Canc by Open)	NO1SO1KO1KT1	NO1SO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
5	Battery Fail	KT1	KT1	Automated SMS	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
6	Mains Failure	KT1	KT1	Automated SMS	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
7	Low Battery	KT1	KT1	Automated SMS	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
8	Polling Fail	NO1SO1KO1KT1	NO1SO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
12	GPRS Fail	KT1	KT1	Automated SMS	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
68	Low Temperature Restore	SO1KO1KT1	SO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
69	Central Polling Lost - GPRS	NO1SO1KO1KT1	NO1SO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
70	Tamper Alarm	NO1SO1KO1KT1	NO1SO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
71	Central Polling Lost	NO1SO1KO1KT1	NO1SO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				
72	Confirmed Intr Canc by Op/Abt	SO1PO1KO1KT1	SO1PO1KO1KT1	Automated SMS/Operator	
	Strategy:Wait Until Contact Becomes Available: - used for 1 action				

Actions	A Special instructions	G General Agency	M Medical Agency	R Report
Key	C Reverse Chanel Command	I Installer	N Information Page	S Site
	F Fire Service	K Key Holder Group	P Police	

No Active Alarm Notes

Transmitter Details

Transmitter No. 1: CSL Connected ARC Conn. Only CS9901

Receiver Type: Digi Air Connected No HardW CS9901

Signalling ID: 005:00:184614

Enabled on 08/09/2024

Connected on 08/09/2024

Alarm Telno: N/A

Panel Password: N/A

Last Signalled on 08/08/2024

Net Address 2: N/A

Line Card 1: No Offset

Password: None

SW Version: N/A

Panel Short Code: N/A

Transmitter Programming

Transmitter No. 1: CSL Connected ARC Conn. Only

Receiver Type: Digi Air Connected No HardW CS99

CS9901

Device Type: Zone/Input	Activation Event	Restore Event
Zone: 1	Fire Alarm	Restore
Zone: 2	Personal Attack	Restore
Zone: 3	Intruder (Canc by Open)	Restore
Zone: 4	Open	Close
Zone: 6	Zone Omit	Restore
Zone: 7	Confirmed Intr Canc by Op/Abt	Restore
Zone: 10	Low Battery	Battery Restore
Zone: 13	Central Polling Lost - GPRS	Central Polling Restore
Zone: 15	GPRS Fail	GPRS Restore
Zone: 8001	Fire Alarm	Restore
Zone: 8002	Personal Attack	Restore
Zone: 8003	Intruder (Canc by Open)	Restore
Zone: 8004	Open	Close
Zone: 8006	Zone Omit	Restore
Zone: 8007	Confirmed Intr Canc by Op/Abt	Restore
Zone: 8010	Low Battery	Battery Restore

Event Conversions

Zone	Is Hex?	Received Event	Converted Event	Adjusted Zone
10		Comms Trouble Restore	Network Restore	10
10		Telco 1 Fault	Network Fail	10
12		Comms Trouble Restore	Line Restore	12
12		Telco 1 Fault	Network Fail	12
8001		Fault	Fire Alarm	8001
8002		Fault	Personal Attack	8002
8003		Fault	Intruder (Canc by Open)	8003
8004		Fault	Open	8004
8004		Restore	Close	8004
8006		Fault	Zone Omit	8006
8010		Fault	Low Battery	8010
8010		Restore	Battery Restore	8010
8007		Fault	Confirmed Intr Canc by Op	8007

No Special Actions Set for this Site

Information Pages

Status: Permanent
Title: Dualcom Digi Air Confirmed + Tamper

Starts:
Expires:

1. GPRS Fail / Radio Pad Fault

LOG ONLY (unless received with another signal then treat as confirmed, must be within same set period and within 96 hours)

2. Single Intruder Alarm

Site/Keyholder Response Only unless received with a signalling fault then treat as a confirmed (must be within same set period and within 96 hours. You will need to show all actions if police are required)

3. Radio Poll Fail

- If received after a GPRS fail - Log only.
- If received with no other signals inform keyholders

4) Any Tamper alarm following an intruder alarm treat as a confirmed (must be within 60 minutes and the intruder must have not restored)..

No User Defined Field Entries