

Engineering Report.

CIA Fire & Security Ltd
Montsam House
11 Love Lane
Cirencester
Glos
GL7 1YG
01285 651025
01285 642155
info@ciafireandsecurity.co.uk



Site Name	Mr S Keswick	Site ID	KE0024
Address	Rockcliffe House Upper Slaughter Cheltenham Glos GL54 2JW		Perdix Partnership 6/7 Wychwood Court Cotswold Business Village Moreton- in- Marsh Glos GL56 0JQ
Contact	Mr S Keswick	Customer Reference	
System Type	- K - Intruder Alarm - BS4737 & DD243		
Call No.	568377	Type	Corrective Appointment
		Reason	Phone Call Log
Description	Directions: 20 mile(s) - leave ciren on stow road at bourton on the water turn left for naunton carry on road until you reach cross roads turn right for stow,drive way is 1/2 mile on left oppissite wooden gates What 3 words - generated.tutored.mermaids Site attendance to run in Cat 5 cable to convert Radio/Radio to Radio IP.		
Started	12/10/23	@	08:26:00
Finished	12/10/23	@	11:45:00
Travel Time			
Remarks	Attended site to look into issues on intruder alarm. Look into changing comms from radio radio path to lan radio , No real easy route to basement switch Customer didn't want any surface cabling Found our bt cable that runs to phone point above switch, Tested cores and ok Made off ends and connected to switch tested cable and Internet connection and can see comms on ip range Got office to email custodian then chased up custodian and csl to change paths Waited a while for this All changed to lan radio now Tested paths All ok Labelled up cable in switch		

Checklist

Checked ? Remarks

Engineer Signature

Customer Signature

Engineer

Michael Uzzell

Name

Mu

Risk Assessment

Checked ?

Remarks

Are all precautions for hazardous substances, dust, noise, dangerous or unstable structures and weather control measures in place? Have you been made aware of any relevant site specific rules & hazards?

Yes

Are sufficient controls in place to prevent unwanted contact with electricity?

Yes

Are suitable controls in place for working at height (i.e. ladders, working platforms, & mobile towers)?

Yes

Are adequate arrangements in place for work near dangerous processes, equipment or for working in or near confined spaces (i.e. Vats, Tanks, Pools, Ponds, Silos & Trenches)?

Yes

Are there any issues for disposal and removal of waste ?

Yes

Do you feel comfortable that all fire risks are controlled?

Yes

Do you feel that all precautions for Lone/Remote Working are suitable and that entry and exit to site is safe and adequate welfare facilities are available (i.e. toilets and rest etc)?

Yes

Are suitable controls in place for any potential hazards regarding contact with animals, potential violent customers, and situations?

Yes